



KITSAP COUNTY DEPARTMENT OF PUBLIC WORKS

614 DIVISION STREET (MS-26), PORT ORCHARD, WA 98366-4699 | KITSAP1: 360.337.5777 | KITSAPGOV.COM

KITSAP COUNTY DEPARTMENT OF PUBLIC WORKS STORMWATER NO. 97003141

SUQUAMISH REGIONAL STORMWATER TREATMENT FACILITY

ADDENDUM # 1

Date of Issue:	March 07, 2025
Date of Opening:	March 18, 2025 (Revised per this Addendum)
Time of Opening:	11:00 AM

1. The **Call for Bids** is amended as follows:

The bid opening date is revised to **March 18, 2025**

2. **Questions have been asked by prospective bidders.** Attached, and part of this addendum, is a Questions and Answers document dated March 7, 2025.

Paper copies of this addendum, and any of the attachments, are available UPON REQUEST. Please call 360-337-5777, or email at help@kitsap1.com to request paper copies. Costs for shipping paper copies shall be borne by the requestor.

This Addendum shall be acknowledged in writing by the bidder in the space provided in the proposal and shall become a part of the Contract Documents.

Addendum Authorized by _____

Joseph P. Rutan, P.E.
County Engineer





KITSAP COUNTY DEPARTMENT OF PUBLIC WORKS

614 DIVISION STREET (MS-26), PORT ORCHARD, WA 98366-4699 | KITSAP1: 360.337.5777 | KITSAPGOV.COM

KITSAP COUNTY DEPARTMENT OF PUBLIC WORKS STORMWATER NO. 97003141

SUQUAMISH REGIONAL STORMWATER TREATMENT FACILITY

Questions & Answers – March 07, 2025 Attachment to ADDENDUM # 1

The County has received Questions from prospective bidders. Below are the County's corresponding answers:

Question: Is there access to the beach through the boat ramp?

Answer: *The county does not have any access rights to the boat ramp through Tribal property. Access to the outfall and county right-of-way at toe of bluff is only available via the top of bluff or via navigable waters.*

Question: Is the bluff wall covered under the same bid item as the anchor/pipe?

Answer: *Yes, the bluff wall, or Trench Bluff Backfill (Detail 3, sheet 11), is covered under Schedule A, bid item A25, for "Outfall Pipe Anchor."*

Question: Will the County be taking care of the Biological Survey during the work window?

Answer: *The County will be responsible for coordinating the biological survey (for Surf Smelt Spawning).*

Question: What is the current water elevation?

Answer: *Based on NOAA Tide Predictions' historical data, the tidal elevation was approximately 8.5 ft (MLLW) at the start of the pre-bid meeting (Port Madison Station 9445753). See Figure 1 below.*






Figure 1 – NOAA Tide Predictions Plot for Tuesday, March 4, 2025.

Question: Will there be any road closures permitted?

Answer: *WB NE Parkway may be closed to traffic to facilitate the work, as shown in the Traffic control plans included in the Contract Provisions. Suquamish Ave may be closed for a maximum duration of 12 hours and not exceeding five (5) closures to facilitate the work. The contractor must submit a road closure request, traffic control plan, and detour plan for review and approval by the county.*

Question: Is there a County ROW permit included?

Answer: *The contractor is responsible for submitting a ROW permit application for the work, but it will be a no-fee permit.*

Question: What are the limits of the trench bluff restoration? There doesn't appear to be item for it, and we're trying to determine quantities.

Answer: *The limits of the trench bluff restoration detail coincide with the contractor's trench excavation limits, if open trenching through the bluff.*

Question: Is the 24-hour leak test of the main treatment vault necessary?

Answer: *The leak test is not required.*

Question: Can the media and mulch be placed prior to putting the lids on?

Answer: *The contractor must follow the manufacturer's recommendations for media placement.*

Question: Can the County provide a copy of the sign-in sheet from the pre-bid meeting?

Answer: Yes, the sign in sheet is attached below.



KITSAP COUNTY DEPARTMENT OF PUBLIC WORKS
 614 DIVISION STREET (MS-26), PORT ORCHARD, WA 98366-4699 | KITSAP: 360.337.5777 | KITSAPGOV.COM

Mandatory Pre-bid Meeting Sign-In Sheet

Project Name: Suquamish Regional Stormwater Treatment Facility

Date: Tuesday, March 4, 2025 at 10:00 AM

Name	Company	Prime	Sub	Phone Number	Email
JEFF ALLEN	Sound Pacific	X		253 444 0650	101@SoundPacificConstruction.com
KETH LARSON	RMDARS	X		509 224 072	John@RedanteConstruction.com
Phillip Navert	GRAVITE Construction	X		425-359-6392	philly.navert@gravite.com
ERIC LORENZEN	NWC	X		253 258 1459	estimating@NWCSCORP.COM
Casey Krapf	Oldcastle		manufactory	706 574 9583	Casey.Krapf@oldcastle.com
Alec Snow	Oldcastle		manufactory	470 313 5072	Alec.Snow@oldcastle.com
Eddie Pettly	ACI	X		253-778-2500	eddie@acturconstruction.com
Brandon McDonald	Ceccanti, Inc.	X		253-537-2990	ed@ceccantiinc.com

ROAD MAINTENANCE • ROAD ENGINEERING • TRANSPORTATION
 SOLID WASTE • SEWER UTILITY • STORMWATER • EQUIPMENT SERVICES • SUPPORT SERVICES • PUBLIC INFORMATION





KITSAP COUNTY DEPARTMENT OF PUBLIC WORKS

614 DIVISION STREET (M5-26), PORT ORCHARD, WA 98366-4699 | KITSAP1: 360.337.5777 | KITSAPGOV.COM

Name	Company	Prime	Sub	Phone Number	Email
Dick Sullivan	Vet Industrial	X		3603772955	Dick.S@vetindustrial.com
COURTNEY SOYRINS	TITAN EARTHWORK LLC	X		253 985 1185	Estimate@TITANearth.com
JESSE GALLIGAN	ORION MARINE CONCRETE, INC	X		360 271 2812	JGALLIGAN@ORIONMARINEGROUP.COM
Hami Babaiyan	Herc Rentals Trench Solutions			252-207-4304	hami.babaiyan@hercrentals.com
Chris Hertz	Herc Rentals Pump & Paver		-	206 247 8264	christopher.hertz@hercrentals.com

ROAD MAINTENANCE • ROAD ENGINEERING • TRANSPORTATION
SOLID WASTE • SEWER UTILITY • STORMWATER • EQUIPMENT SERVICES • SUPPORT SERVICES • PUBLIC INFORMATION





KITSAP COUNTY DEPARTMENT OF PUBLIC WORKS

614 DIVISION STREET (MS-26), PORT ORCHARD, WA 98366-4699 | KITSAP: 360.337.5777 | KITSAPGOV.COM

Name	Company	Prime	Sub	Phone Number	Email
Mandy Perez	Gary Harper Construction	GHC		206-843-5057	Gary@garyharperconst.com mandy@garyharperconst.com
KELSON MCCLUNG	MCCLUNG CONSTRUCTION Co.	✓		360-397-9049	BIDSMCCLUNGCONSTRUCTION.COM
TOM JOHNSON	NOROLAND CONSTRUCTION NW	✓		360-774-1274	NOROLANDCONSTRUCTIONNW @HOTMAIL.COM

ROAD MAINTENANCE · ROAD ENGINEERING · TRANSPORTATION
SOLID WASTE · SEWER UTILITY · STORMWATER · EQUIPMENT SERVICES · SUPPORT SERVICES · PUBLIC INFORMATION





KITSAP COUNTY DEPARTMENT OF PUBLIC WORKS

614 DIVISION STREET (MS-26), PORT ORCHARD, WA 98366-4699 | KITSAP1: 360.337.5777 | KITSAPGOV.COM

Name	Company	Prime	Sub	Phone Number	Email
Brandon Payne	Interwest const.	✓		360-757-7574	bids@interwest.biz
Jack Melbauer	Hess Rentals			253-316-7713	Jack.Melbauer@hessrentals.com

ROAD MAINTENANCE · ROAD ENGINEERING · TRANSPORTATION
SOLID WASTE · SEWER UTILITY · STORMWATER · EQUIPMENT SERVICES · SUPPORT SERVICES · PUBLIC INFORMATION

