

GENERAL INFORMATION

The Stormwater Pollution Prevention Plan (SWPPP) shall follow the format requirements of Site Improvement Plans (see Section 1.2.2) and shall contain the following information:

- Plans sheets: Minimum sheet size is 18" x 24". (11" x 17" acceptable for small project SWPPs where no SDAP is required)
- Scale: Preferred horizontal scales are 1"=20', 1"=30', 1"=40', or 1"=50'. Minimum scale is 1"=100'. (Scale should be as large as plan sheet size can comfortably accommodate).
- Location of Flow Control BMPs—Show on the site plans the locations of any Flow Control Best Management Practices (BMP).
- Erosion and Sediment Control (ESC) BMPs—Show on the site plans all major structural and nonstructural ESC BMPs including:
 - The location, detail, and specification for silt fence.
 - The construction entrance location and a detail.
- Other pollutant BMPs—Indicate on the site map the location of BMPs to be used for the control of pollutants other than sediment.
- North arrow.
- Existing structures (buildings, parking lots and driveways, etc.) to remain.
- Existing natural features such as wetlands, streams, slopes and their associated buffers and applicable construction setbacks.
- Name, address, and telephone of the owner, applicant and agent.
- Assessor's Tax parcel number.
- Vicinity map of sufficient clarity to locate the property.
- Symbol legend.
- Show the location and limits of all existing and proposed:
 - Property boundaries with dimensions
 - Structures and other impervious surfaces such as parking lots, driveways, patios, buildings, etc.
 - Roads and right-of-way including roadway and right-of-way widths, surfacing and road names.
 - Sanitary sewers and water utilities.
 - Common open space.
 - Public dedications.
 - Other manmade features affecting existing topography or proposed improvements.
 - Easements and tracts.
- The location of on-site and adjacent off-site waste treatment systems, such as septic tanks and distribution systems, and on-site and adjacent off-site wells and underground storage tanks, all in accordance with Kitsap County Health Department regulations.
- Proposed limits of land-disturbing activity.
- Flows—Provide arrows that indicate the direction of surface flow on all public and private property and for all existing conveyance systems.
- Existing topography.
- Finished grade.
- The phasing of any erosion and sedimentation control work clearly indicated on the Plan.
- Areas of potential erosion problems.
- Locations where stormwater discharges to surface waters during and upon completion of construction.

STANDARD DETAILS

CONSTRUCTION ACCESS

EXISTING ROAD
R=25 MIN
4" - 8" QUARRY SPALLS
GEO-TEXTILE FABRIC
8" MIN. THICKNESS
50' MINIMUM LENGTH
15' MIN
PROVIDE FULL WIDTH INGRESS / EGRESS AREA

NOTE: STABILIZED ACCESS SHALL BE USED IN ALL AREAS OF THE SITE WITH VEHICLE TRAFFIC AND PARKING

CONCRETE CONTAINMENT AREA

PRE-MANUFACTURED CATCH BASIN OR INLET INSERT

NOTES:

- STORM DRAIN INLETS NEED TO BE REMOVED AT THE END OF THE JOB.
- STORM DRAIN INLETS ARE ONLY TO BE INSTALLED IN DRAINAGE DEVICES PER THE MANUFACTURER'S RECOMMENDATIONS. CATCH BASIN INSERTS ARE NOT TO BE INSTALLED IN CURB INLETS.
- INSERTS SHALL BE INSPECTED AND MAINTAINED WHEN A 1/2 INCH OF RAIN ACCUMULATES WITHIN A 24 HOUR PERIOD. CLEAN AND / OR REPLACE INSERT WHEN HALF OF THE TRAP IS FILLED WITH SEDIMENTS.

STORM DRAIN INLET (INSERT)

I agree to meet each requirement noted above and to use each stormwater control shown on the Site Plan to prevent erosion and sediment from leaving the site. I understand that I may be required to use additional controls if the controls on the site plan are not sufficient to prevent erosion or the transport of sediment or other pollutants from the site.


Signature _____
Date _____

Site Plan

Check Scale Used

- one square = one foot
- one square = two feet
- one square = three feet

Kitsap County Department of Community Development
Storm Water Pollution Prevention Plan (SWPPP - Small Project)



SWPPP STANDARD PLAN





















Applicant, Owner or Agent

Name: _____

Building Permit #. _____

LEGEND

(USE AS NECESSARY)

-  P L Property Line
-  Break Line
(use to compress drawing)
-  Existing House Building
(Label Existing or Proposed or Future)
-  Primary Septic Drainfield
(Label Primary or Reserve)
-  C L Clearing Limits / Limit of Disturbed Area
-  N B Z No Build Zone (setback)
-  Existing Road or Driveway
(label Existing or Proposed)
-  P-W-T-G Power, Water, Telephone, Gas
-  Slope (downward)
-  Elevation Control
(Temporary Bench Mark)
-  127 Spot Elevation
-  x-x-x-x Fence
-  SF SF Silt Fence
(Filter Fabric Fence)
-  Culvert or Pipe
(Label Existing or Proposed)
-  Catch Basin
(Label Existing or Proposed)
-  CK ST Creek or Stream
-  Ditch or Swale
-  C F Grading (Cut or Fill)
-  Rockery
-  Wetland